

City Planning Case Referral



Project Information

LA Sanitation Case Referral #: 1045 S. olive

Date: 7-31-17

| | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Site Information</p> <p>Project Address: <u>1045 S. olive</u></p> <p>APN: <u>5139010002</u></p> <p>Type of Project: <u>New</u> Redevelopment</p> <p>• Res. / Comm. / Ind. / <u>Mixed Use</u></p> <p>• Other: <u>2017-32514</u></p> <p>Hillside Grading: (Y / <input checked="" type="radio"/> N) ESA: (Y / <input checked="" type="radio"/> N)</p> <p>Liquefaction: (Y / <input checked="" type="radio"/> N)</p> <p>Percolation test done: (<input checked="" type="radio"/> Y, N) <u>Conductor</u></p> | <p>Applicant Information</p> <p>Name: <u>1045 S. Olive, David Evans & Associates</u></p> <p>Email: <u>taylor.miller@deoinc.com</u></p> <p>Phone: <u>213-337-3689</u></p> <p>Address: <u>201 S Figueroa St, Suite 240</u> <u>Los Angeles, CA 90012</u></p> |
| <p>Project Information</p> <p>Total site area (Ac): _____ Design Storm (85th Percentile): <u>1.0 in</u></p> <p>Approx Impervious area (Ac): _____ Approx Pervious Area (Ac): _____</p> | |
| <p>Note: The information on this City Planning Case Referral Form is only a "preliminary review" by LA Sanitation. It informs the applicant of the stormwater requirements that will need to be implemented on the project in order to satisfy Low Impact Development (LID) requirements.</p> | |
| <p>Possible BMP (Subject to Soils testing and Site conditions)</p> <p>Infiltration: (<input checked="" type="radio"/> Y) N Capture & Use: (Y / N)</p> <p>Bio-Filtration: (Y / N)</p> | <p>Sanitation Plan Checker</p> <p>Reviewer: <u>Mike Sandoval</u></p> <p>Date Reviewed: <u>7-31-17</u></p> |
| <p>Comment(s):</p> <p><u>LID Requirements -> must provide percolation test for infiltration.</u></p> | |