

# City Planning Case Referral



## Project Information

LA Sanitation Case Referral #: 1045 S. olive Date: 7-31-17

<p><b>Site Information</b></p> <p>Project Address: <u>1045 S. olive</u></p> <p>APN: <u>5139010002</u></p> <p>Type of Project: <input checked="" type="radio"/> <u>New</u> / <input checked="" type="radio"/> <u>Redevelopment</u></p> <ul style="list-style-type: none"> <li>• Res. / Comm. / Ind. / <input checked="" type="radio"/> <u>Mixed Use</u></li> <li>• Other: _____</li> </ul> <p>Hillside Grading: (Y / <input checked="" type="radio"/> N)      ESA: (Y / <input checked="" type="radio"/> N)</p> <p>Liquefaction: (Y / <input checked="" type="radio"/> N)</p> <p>Percolation test done: (<input checked="" type="radio"/> Y, N) <u>Conduct</u></p>	<p><b>Applicant Information</b></p> <p>Name: <u>1045 Olive, David Evans &amp; Associates</u></p> <p>Email: <u>taylor.miller@deinc.com</u></p> <p>Phone: <u>213-337-3689</u></p> <p>Address: <u>201 S Figueroa St, Suite 240</u> <u>Los Angeles, CA 90012</u></p>
<p><b>Project Information</b></p> <p>Total site area (Ac): _____ Design Storm (85<sup>th</sup> Percentile): <u>1.0 in</u></p> <p>Approx Impervious area (Ac): _____ Approx Pervious Area (Ac): _____</p>	
<p><b>Note:</b> The information on this City Planning Case Referral Form is only a "preliminary review" by LA Sanitation. It informs the applicant of the stormwater requirements that will need to be implemented on the project in order to satisfy Low Impact Development (LID) requirements.</p>	
<p><b>Possible BMP</b> (Subject to Soils testing and Site conditions)</p> <p>Infiltration: (<input checked="" type="radio"/> Y) N      Capture &amp; Use: (Y / N)</p> <p>Bio-Filtration: (Y / N)</p>	<p><b>Sanitation Plan Checker</b></p> <p>Reviewer: <u>Mike Sawicki</u></p> <p>Date Reviewed: <u>7-31-17</u></p>
<p><b>Comment(s):</b></p> <p><u>LID Requirements -&gt; must provide percolation test for infiltration.</u></p>	