

From: Albert Lew <albert.lew@lacity.org>
Sent time: 08/10/2018 03:02:41 PM
To: Rickard Severinsson <rickard.severinsson@kpff.com>
Cc: Sunbula Azieh <sunbula.azieh@lacity.org>; Christopher DeMonbrun <chris.demonbrun@lacity.org>; Miriam Huston <miriam.huston@kpff.com>
Subject: Re: Sewer Capacity Availability Request (SCAR) Ref.# 2482

Hello Rickard,

We received your reply. Since the original SCAR was already approved and sent, we will need to make a new SCAR to accommodate the change.

We will incorporate the new changes into a new SCAR as you showed us in the PDF and upon approval, it will serve as the one you can use (SCAR 2482 will be void then)

We anticipate the new one SCAR to be done by early next week. We'll keep you posted.

Thanks,
Albert

Albert C. Lew, P.E.

Wastewater Engineering Services Division (WESD)
Bureau of Sanitation
Department of Public Works
City of Los Angeles
Phone: 323.342.6207
Fax: 323.342.6210



-----Confidentiality Notice-----

This electronic message transmission contains information from the City of Los Angeles, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited.
If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.

On Fri, Aug 10, 2018 at 8:33 AM, Rickard Severinsson <rickard.severinsson@kpff.com> wrote:

Hello Sunbula,

Thank you for sending over the SCAR.

I noticed that BOE had input the wrong square footage for the office building, they also missed to add the conference rooms. The total flow should be 322,067 GPD. Please see attached SCAR for the corrections.

Is it possible to add a note in the remarks saying this is the most conservative option?

Thanks,



Rickard Severinsson, EIT

Project Manager

☎ 213.418.0201 📠 213.266.5277

700 South Flower Street, Suite 2100

Los Angeles, CA 90017

rickard.severinsson@kpff.com

From: Sunbula Azieh [mailto:sunbula.azieh@lacity.org]

Sent: Tuesday, August 07, 2018 7:31 AM

To: Rickard Severinsson <rickard.severinsson@kpff.com>

Cc: Christopher DeMonbrun <chris.demonbrun@lacity.org>; Albert Lew <albert.lew@lacity.org>

Subject: Sewer Capacity Availability Request (SCAR) Ref.# 2482

Good morning,

We had received your SCAR Application -1720-1724 Vine St, 1746-1764 Ivar Ave, 6334 Yucca St, 1733-1741 Argyle. I want to let you know that our department needs to collect gauging information to review your application.

The gauging process will take up to two weeks. As soon as we have those results, we will continue with this review.

Please contact us at your earliest convenience if you have any question.

Thank you,

Sunny

--

Sunbula Azieh


**Wastewater Engineering Services Division - LA Sanitation
City of Los Angeles - Department of Public Works**

2714 Media Center Dr
Los Angeles, CA 90065

[E-mail:Sunbula.Azieh@lacity.org](mailto:Sunbula.Azieh@lacity.org)

Tel: (323) 342-6231

Fax: (323) 342-6210



-----Confidentiality Notice-----

This electronic message transmission contains information from the City of Los Angeles, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited.

If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.