

From: Ricardo Avendano <ricardo.avendano@lacity.org>
Sent time: 09/05/2018 09:32:56 AM
To: Albert Lew <albert.lew@lacity.org>
Subject: Re: CEQA Response: Hollywood Center Project – Notice Of Preparation of Environmental Impact Report and Public Scoping Meeting

Thank you. When reviewing a CEQA, as far as I understand is that Primary Group should be informed if the flow is more than 30,000 GPD, however in case you have an industrial discharge in the analysis, there is no need at this time to request and IWP. Please correct me if I am wrong.

Jose Ricardo Avendano
Bureau of Sanitation
Wastewater Engineering Services Division
Office # 323-342-6227
Cell. # 626-372-4456
ricardo.avendano@lacity.org

On Wed, Sep 5, 2018 at 9:26 AM, Albert Lew <albert.lew@lacity.org> wrote:

Don't forget the IWP for the restaurant in this project.

Good work.

Albert C. Lew, P.E.

Wastewater Engineering Services Division (WESD)
Bureau of Sanitation
Department of Public Works
City of Los Angeles
Phone: 323.342.6207
Fax: 323.342.6210



-----Confidentiality Notice-----

This electronic message transmission contains information from the City of Los Angeles, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited.
If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.

On Wed, Sep 5, 2018 at 8:38 AM, Ricardo Avendano <ricardo.avendano@lacity.org> wrote:

Here is the Hydraulic Analysis Map.

Jose Ricardo Avendano
Bureau of Sanitation
Wastewater Engineering Services Division
Office # 323-342-6227
Cell. # 626-372-4456
ricardo.avendano@lacity.org

On Wed, Sep 5, 2018 at 8:37 AM, Ricardo Avendano <ricardo.avendano@lacity.org> wrote:

Please review the project stated above for Notice of Preparation of Environmental Impact Report.

\\82mtcfs1\wesd\Div Files\SCAR\CEQA Review\CEQA Analysis Files\Hydraulic Analysis\Hollywood Center Project - NOP of EIR

\\82mtcfs1\wesd\Div Files\SCAR\CEQA Review\FINAL CEQA Response LTRs\FINAL DRAFT\Hollywood Center Project – NOP of EIR and Public Scoping Meeting

Jose Ricardo Avendano
Bureau of Sanitation
Wastewater Engineering Services Division
Office # 323-342-6227
Cell. # 626-372-4456
ricardo.avendano@lacity.org