

From: Christine Heinrich-Josties <christine.heinrich@lacity.org>
Sent time: 03/03/2020 09:46:47 AM
To: Sunbula Azieh <sunbula.azieh@lacity.org>
Cc: Christopher DeMonbrun <chris.demonbrun@lacity.org>; Albert Lew <albert.lew@lacity.org>; Anthony Soriano <anthony.soriano@lacity.org>
Subject: Re: Primary Approval: SCAR #64-5048-0220 - 1720-1724 VINE ST, 1746-1764 IVAR AVE, 6334 YUCCA ST, 1733-1741 ARGYLE

Hi Sunny,

To confirm, the combined flow you are seeking primary approval for is: 322,066, correct?

Let me know. Thanks!

Regards,

Christine Heinrich-Josties, P.E.

Environmental Engineering Associate IV
Wastewater Engineering Services Division
2714 Media Center Drive
Los Angeles, CA 90065
Phone: 323-342-1574
christine.heinrich@lacity.org



-----Confidentiality Notice-----

This electronic message transmission contains information from the City of Los Angeles, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited.
If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.

On Mon, Mar 2, 2020 at 2:29 PM Sunbula Azieh <sunbula.azieh@lacity.org> wrote:

Hi Christine,

Please review the following project discharges for approval.

Project Name: 1720-1724 VINE ST, 1746-1764 IVAR AVE, 6334 YUCCA ST, 1733-1741 ARGYLE
Job Address: 1720-1724 VINE ST, 1746-1764 IVAR AVE, 6334 YUCCA ST, 1733-1741 ARGYLE
SCAR ID: 64-5048-0220

1st Discharge:

1720-1724 VINE ST:
Primary Sewer MH#: 46914036
Primary Basin: Hollywood
Proposed Flow (GPD): 154,592
d/D:0.51
Connection: permanent

2nd Discharge:

6334 YUCCA ST
Primary Sewer MH#: 49301023
Primary Basin: Hollywood
Proposed Flow (GPD): 16,103 GPD
d/D:0.22
Connection: permanent

3rd Discharge:

1746-1764 IVAR AVE
Primary Sewer MH#: 46914036
Primary Basin: Hollywood
Proposed Flow (GPD): 83,737 GPD

d/D:0.41

Connection: permanent

4th Discharge:

1733-1741 ARGYLE

Primary Sewer MH#: 46914105

Primary Basin: Hollywood

Proposed Flow (GPD): 67,634 GPD

d/D:0.41

Connection: permanent

Thanks,

Sunny

--

Sunbula Azieh

Wastewater Engineering Services Division - LA Sanitation

City of Los Angeles - Department of Public Works


2714 Media Center Dr

Los Angeles, CA 90065

[E-mail:Sunbula.Azieh@lacity.org](mailto:Sunbula.Azieh@lacity.org)

Tel: (323) 342-6231

Fax: (323) 342-6210



-----Confidentiality Notice-----

This electronic message transmission contains information from the City of Los Angeles, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited.

If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.