

**From:** [Jessie Fan](#)  
**To:** [Hwang, Jin](#)  
**Subject:** Hollywood Center - WSA  
**Date:** Monday, December 24, 2018 4:37:10 PM  
**Attachments:** [image001.png](#)

---

Hi Jin,

Hope that all is well. I'm reviewing the WSA that was provided, and I noticed that the residential lounge didn't get a calculation (see circle below). Does that need to be amended? It would be about 220 gpd, not accounting for required savings. Please let us know at your earliest convenience. Thanks!

<b>West Site</b>					
<b>Market-Rate</b>					
Lobby	7,535	sf	0.05		377
Health Club	5,784	sf	0.65		3,760
Office	3,957	sf	0.12		475
Lounge	14,047	sf	0.05		702
Bar	2,470	sf	0.72		1,778
<b>Senior Affordable</b>					
Lobby	1,287	sf	0.05		64
Lounge	1,895	sf	0.05		95
<b>East Site</b>					
<b>Market-Rate</b>					
Hotel Lobby	3,227	sf	0.05		161
Residential Lobby	3,021	sf	0.05		151
Hotel Back of the House <sup>8</sup>	1,956	sf			
Hotel Health Club	1,150	sf	0.65		748
Residential Health Club	6,807	sf	0.65		4,425
Hotel Conference Rooms	2,907	sf	0.12		349
Residential Lounge	4,389	sf	0.05		

Jessie Fan  
Senior Associate  
ESA | Environmental Science Associates  
80 South Lake Avenue, Suite 570  
Pasadena, CA 91101  
626.204.6170 main | 626.204.6171 fax  
626.714.4611 direct  
[JFan@esassoc.com](mailto:JFan@esassoc.com) | [www.esassoc.com](http://www.esassoc.com)

Follow us on [Facebook](#) | [Twitter](#) | [LinkedIn](#)