Subject: RE: DKN Ventura Hotel - Geotech
Date: Monday, March 16, 2020 at 11:27:39 AM Mountain Daylight Time
From: Jon Browning
To: AshikaD@dknhotels.com, Fred David
CC: Kerrie Nicholson, Paul Soltis, Benito Caban
Attachments: image001.jpg

Fred and Ashika,

Based on review of the attached report, there are no known faults mapped on the subject site. Based on review of the laboratory test results, the on-site clayey soils posses a very low to low expansion potential.

Please feel free to contact us if you have any further questions.

Thanks,

Jonathan Browning
PG, CEG
Senior Project Manager

Twining Consulting, Inc. Quality, Service, Integrity
18011 Sky Park Circle, Suite J, Irvine, CA 92614
O: 949.553.0370 | D: 949.732.6139 | M: 619.379.9096 | F: 949.553.0371
jbrowning@twiningconsulting.com | www.twiningconsulting.com
Facebook | Instagram | LinkedIn

From: Paul Soltis <PSoltis@twininginc.com>
Sent: Monday, March 16, 2020 9:41 AM
To: Jon Browning <jbrowning@twiningconsulting.com>
Cc: Benito Caban <bcaban@twiningconsulting.com>
Subject: FW: DKN Ventura Hotel - Geotech

Jon,

Can you please take a look at this and answer the question from CAJA below?

Thanks
Paul

From: Fred David <FredD@dknhotels.com>
Sent: Monday, March 16, 2020 9:01 AM
To: Ashika Dahya-Keshav <AshikaD@dknhotels.com>; Paul Soltis <PSoltis@twininginc.com>
Subject: RE: DKN Ventura Hotel - Geotech

EXTERNAL EMAIL - CAUTION

Good Morning Paul,

Hope all is well with you. I'm following up on the inquiry below. Would you mind reviewing the attached evaluation to answer Kerrie's email below?

Thank You,

Fred David | design + construction
714.427-4377 | fredd@dknhotels.com
DKNHOTELS
A PASSION TO MAKE A DIFFERENCE

From: Ashika Dahya-Keshav
Sent: Monday, March 9, 2020 11:35 AM
To: Paul Soltis <psoltis@twininginc.com>
Cc: Fred David <FredD@dknhotels.com>
Subject: FW: DKN Ventura Hotel - Geotech

Hi Paul,

Please see the email request from CAJA environmental below, regarding the AC Sherman Oaks. I don't see a reference to what she states in the attached report – can you please provide an email or memo response?

Thanks,

Ashika Dahya-Keshav | design + construction
714.222-7705 | ashikad@dknhotels.com
DKNHOTELS
A PASSION TO MAKE A DIFFERENCE

From: Kerrie Nicholson <kerrie@ceqa-nepa.com>
Sent: Monday, March 9, 2020 11:29 AM
To: Ashika Dahya-Keshav <AshikaD@dknhotels.com>; Fred David <FredD@dknhotels.com>
Subject: DKN Ventura Hotel - Geotech

Hi Ashika:

Will you please ask Twining Consulting to specify whether there are any known faults at the Project Site and whether the soils at the Project Site are considered "expansive?" The response can be in an email or a memo.

Thank you.

--
Kerrie Nicholson, Principal
CAJA Environmental Services, LLC

15350 Sherman Way, Suite 315
Van Nuys, CA 91406
Direct: 310-469-6706
Cell: 310-990-7700
Email: Kerrie@ceqa-nepa.com